


## FLOW MEASUREMENT SYSTEM / INSTALLATION INSTRUCTIONS



\*Consult factory for recommendations when space is limited.

- 1. Note the directional arrow on the venturi and make sure the flow is in the direction of the arrow.
- 2. Position the venturi so that the taps are not pointing straight up, or straight down, but preferably in a horizontal direction.
- 3. Red quick connect assembly should be installed on red, or upstream, tap.
- 4. Green quick connect assembly should be installed on green, or downstream, tap.
- 5. Tag should hang through the insulation, if present, to have station information readily available.
- 6. Venturis can be installed in horizontal, vertical, or inclined pipe lines.

Photo at right shows a reading with flow meter on an insulated water line

Far right photo shows a reading with the flow meter on an uninsulated portion of another water line.

